CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/KRIDL/W.No.15/CSR-04/820f/CEMENT/2015-16 Date: 22.04.2015

TEST REPORT ON CEMENT

* CUSTOMER	:	**Asst. Executive Engineer,** T. Dasarahalli Sub Division, BBMP, Bangalore.
*AGENCY	:	**Technical Manager (West),** KRIDL, Bangalore.
*NAME OF THE WORK	:	Improvements and construction of CC road and drain at Chikkegowda House Road in Ward No. 15, BBMP, Bangalore.
REFERENCE	:	EE/DZ/WO/306/2014-15 Dated: 25.03.2015
SAMPLE ID	:	Cement
SAMPLE RECEIVED ON	:	20.04.15
PERIOD OF TESTING	:	20.04.2015 to 22.04.2015

The results of the tests conducted on the cement sample are as follows:

Sl. No	Descriptions	Test Method as per IS	Test Result	Requirements as per IS: 8112-2013
1	Standard Consistency	IS-4031 (Part -4) 1988(RA-2009)	28.50 %	-
2	a) Initial Setting Time	IS-4031 (Part -5) 1988(RA-2009)	145 Minutes	Not Less than 30 Minutes
	b) Final Setting Time	IS-4031 (Part -5) 1988(RA-2009)	460 Minutes	Not More than 600 Minutes
3	Soundness by Le Chartlier Method	IS-4031 (Part-3) 1988(RA-2009)	1 mm	Not more than 10mm

*Information is furnished by the Customer/Representative.

Civil-Tech Consultants & Engineers Bangalore

Note:

⇒ The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒ The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒ Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH. I.A.
Chief Executive Officer

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಟಿ.ದಾಸರಹಳ್ಳಿ ಉಪ-ವಿಭಾಗ
ಬಾಗಲಗುಂಟೆ. ಬಿಬಿಎಂಪಿ
ಬೆಂಗಳೂರು

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/KRIDL/W.No.15/CSR-04/820f/SAND-Gradation/2015-16 : 22.04.2015

TEST REPORT ON DETERMINATION GRADATION OF FINE AGGREGATES

* Customer : Asst. Executive Engineer, T. Dasarahalli Sub Division, BBMP, Bangalore.

* Agency : Technical Manager (West), KRIDL, Bangalore.

* Name of Work : Improvements and construction of CC road and drain at Chikkegowda House Road in Ward No. 15, BBMP, Bangalore.

Reference : EE/DZ/WO/306/2014-15 Dated: 25.03.2015

Technical Reference : IS : 2386 Part 1 - 1963 RA-2007

Sample ID : Fine Aggregates

Sample Received on : 20.04.2015

Date of Testing : 22.04.2015

DB-15

Total Wt. of Aggregates in gms 1000

Is Sieve Size in mm	Cumulative Weight Passing in %	Specific Limits as per IS 383-1970 (RA- 2007)			
		Zone-I	Zone-II	Zone-III	Zone-IV
10	100	100	100	100	100
4.75	92.70	90-100	90-100	90-100	95-100
2.36	79.50	60-95	75-100	85-100	95-100
1.18	54.20	30-70	55-90	75-100	90-100
600 Micron	22.40	15-34	35-59	60-79	80-100
300 Micron	10.30	5-20	8-30	12-40	15-50
150 Micron	3.80	0-10	0-10	0-10	0-15

* Information is furnished by the Customer/Representative

Civil-Tech Consultants & Engineers Bangalore

Remarks : This sample is under Zone-I specific limits.

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH. I.A.
Chief Executive Officer

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಟಿ.ದಾಸರಹಳ್ಳಿ ಉಪ-ವಿಭಾಗ
ಬಾಗಲಗುಂಟೆ, ಬಿಬಿಎಂಪಿ
ಬೆಂಗಳೂರು

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

41

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/KRIDL/W.No.15/CSR-04/820f/AGG/GR/2015-16 : 22.04.2015

TEST REPORT ON DETERMINATION GRADATION OF COARSE AGGREGATES

* Customer : Asst. Executive Engineer, T. Dasarahalli Sub Division, BBMP, Bangalore.

* Agency : Technical Manager (West), KRIDL, Bangalore.

* Name of Work : Improvements and construction of CC road and drain at Chikkegowda House Road in Ward No. 15, BBMP, Bangalore.

Reference : EE/DZ/WO/306/2014-15 Dated: 25.03.2015

Technical Reference : IS : 2386 Part 1 -1963 RA-2007

Sample ID : Coarse Aggregates (40mm)

Sample Received on : 20.04.2015

Date of Testing : 22.04.2015

Total Wt. of Aggregates in gms= **10000**

Is Sieve Size in mm	Cumulative Weight Passing in %	Specific Limits as per IS 383-1970 (RA- 2007)	
		Graded	Single Sized
80	100	100	-
63	100	-	100
40	96.85	95-100	85-100
20	44.49	30-70	0-20
10	20.60	10-35	0-5
4.75	1.82	0-5	-

* Information is furnished by the Customer/Representative

Remarks : This sample is under graded specific limits.

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH. I.A.
Chief Executive Officer

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಟಿ.ದಾಸರಹಳ್ಳಿ ಉಪ-ವಿಭಾಗ
ಬಾಗಲಗುಂಟೆ, ಬಿಬಿಎಂಪಿ
ಬೆಂಗಳೂರು

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

40

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/KRIDL/W.No.15/CSR-04/820f/CC Solid Block/2015-16 : 27.04.2015

TEST REPORT ON SOLID CONCRETE BLOCKS

Name of Client	: Asst. Executive Engineer, T. Dasarahalli Sub Division, BBMP, Bangalore.
Agency	: Technical Manager (West), KRIDL, Bangalore.
* Name of the Work	: Improvements and construction of CC road and drain at Chikkegowda House Road in Ward No. 15, BBMP, Bangalore.
Reference	: EE/DZ/WO/306/2014-15 Dated: 25.03.2015
Sample Received on	: 22.04.2015
Date of Testing	: 27.04.2015
Size of Blocks	: 400mm x 200mm x 200mm
Cross Sectional Area	: 80000 mm^2
Technical Reference	: IS: 2185 (Part 1) - 2005
No. of Blocks Tested	: 08

Sl.No.	Block ID	Wt. in Kg	Failure load (KN)	Compressive strength (N/mm^2)	Requirement as per IS 2185 (Part 1) - 2005
1	Block 1	35.28	263.7	3.30	Minimum required Compressive Strength of Individual Units 3.20 N/mm^2
2	Block 2	33.69	262.4	3.28	
3	Block 3	34.18	264.8	3.31	
4	Block 4	35.24	265.3	3.32	
5	Block 5	35.98	261.8	3.27	
6	Block 6	36.43	263.5	3.29	
7	Block 7	34.87	261.9	3.27	
8	Block 8	35.52	264.3	3.30	

*Information is furnished by the Customer/Representative.

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH. I.A.
Chief Executive Officer

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಟಿ.ದಾಸರಹಳ್ಳಿ ಉಪ-ವಿಭಾಗ
ಬಾಗಲಗುಂಟೆ, ಬಿಬಿಎಂಪಿ
ಬೆಂಗಳೂರು

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/KRIDL/W.No.15/CSR-04/820f/Pre slab/2015-16 18.05.2015

TEST REPORT ON CONCRETE CORE (PRECAST SLAB)

* Name of Client	:	**Asst. Executive Engineer,** T. Dasarahalli Sub Division, BBMP, Bangalore.
* Name of Agency	:	**Technical Manager (West),** KRIDL, Bangalore.
* Name of work	:	Improvements and construction of CC road and drain at Chikkegowda House Road in Ward No. 15, BBMP, Bangalore.
Referece	:	EE/DZ/WO/306/2014-15 Dated: 25.03.2015
Techinical Reference	:	IS:516-1959 (Reaffirmed 2008), SP-24:1983.
Sample ID	:	Precast Slab
Sample received on		13.05.2015
Date of Testing	:	18.05.2015
Grade of Concrete	:	M_{20}

Sl. No.	Dia of Core D (mm)	Height of Core H (mm)	Core Wt (Kg)	Density of Core (kg / m^3)	H / D	Correction factor (Based on H/D)	Failure Load (kN)	Core Strength (N/mm^2)	Correction Factor for the Dia. (Strength of the Core x 1.08)	Corrected Cylinder Compressive Strength (N/mm^2)	Equivalent Cube Compressive Strength (N/mm^2)
1	50.00	82.00	0.407	2527.85	1.64	0.950	32.23	16.41	17.73	16.84	21.05
2	50.00	80.00	0.399	2540.11	1.60	0.960	32.48	16.54	17.87	17.15	21.44
3	50.00	81.00	0.407	2559.05	1.62	0.955	33.17	16.89	18.24	17.42	21.78

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported reported within 30days from the date of testing.

Civil-Tech Consultants & Engineers Bangalore

****

VISHWANATH. I.A.
Chief Executive Officer

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಟಿ.ದಾಸರಹಳ್ಳಿ ಉಪ-ವಿಭಾಗ
ಬಾಗಲಗುಂಟೆ, ಬಿಬಿಎಂಪಿ
ಬೆಂಗಳೂರು

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/KRIDL/W.No.15/CSR-04/820f/CUBE/2015-16 25.05.2014

TEST REPORT ON COMPRESSIVE STRENGHT OF CONCRETE CUBES

*** Client** : **Asst. Executive Engineer,** T. Dasarahalli Sub Division, BBMP, Bangalore.

*** Agency** : **Technical Manager (West),** KRIDL, Bangalore.

*** Name of the work** : Improvements and construction of CC road and drain at Chikkegowda House Road in Ward No. 15, BBMP, Bangalore.

*** Reference** : EE/DZ/WO/306/2014-15 Dated: 25.03.2015

*** Sample ID** : Cement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

*** Grade of Concrete** : M_{15}

Compressive Strength as o : 28^{th} day

Sample Received on : 27.04.2015

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	27.04.2015	25.05.2014	8.154	362.4	16.11
2	27.04.2015	25.05.2014	8.196	391.2	17.39
3	27.04.2015	25.05.2014	8.247	378.5	16.82

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH. I.A.
Chief Executive Officer

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಭಿಯಂತರರು
ಟಿ.ದಾಸರಹಳ್ಳಿ ಉಪ-ವಿಭಾಗ
ಬಾಗಲಗುಂಟೆ, ಬಿಬಿಎಂಪಿ
ಬೆಂಗಳೂರು

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

NABL - Accredited Laboratory as per ISO / IEC-17025 :2005

T-2377

Job No.: CTCE/BBMP/KRIDL/W.No.15/CSR-04/820f/CUBE/2015-16 25.05.2015

TEST REPORT ON COMPRESSIVE STRENGHT OF CONCRETE CUBES

*** Client** : **Asst. Executive Engineer,** T. Dasarahalli Sub Division, BBMP, Bangalore.

*** Agency** : **Technical Manager (West),** KRIDL, Bangalore.

*** Name of the work** : Improvements and construction of CC road and drain at Chikkegowda House Road in Ward No. 15, BBMP, Bangalore.

*** Reference** : EE/DZ/WO/306/2014-15 Dated: 25.03.2015

*** Sample ID** : Cement Concrete

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

*** Grade of Concrete** : M_{15}

Compressive Strength as o: 28^{th} day

Sample Received on : 27.04.2015

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	27.04.2015	25.05.2015	8.263	386.9	17.20
2	27.04.2015	25.05.2015	8.163	371.4	16.51
3	27.04.2015	25.05.2015	8.316	402.7	17.90

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

****

VISHWANATH. I.A.
Chief Executive Officer

ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಅಧಿಯಂತರರು
ಟಿ.ದಾಸರಹಳ್ಳಿ ಉಪ-ವಿಭಾಗ
ಬಾಗಲಗುಂಟೆ. ಬಿಬಿಎಂಪಿ
ಬೆಂಗಳೂರು

#23/14, 7th Cross, 3rd Stage, 4th Block, Shakthi Ganapathi Nagara, Basaveshwaranagar, Bangalore-79.
Tele Fax : 23223227, Website : www.civiltechconsultants.com
E-mail : vishwanath.ia@civiltechconsultants.com / info@civiltechconsultants.com